

Scheduled maintenance for feedwater pump FP-200, revision B.

Perform the full service procedure every 1,500 operating hours.

Before replacing the mechanical seal, isolate the unit and fully depressurise the casing. Confirm zero pressure at gauge PG-11 before removing any fastener.

The pump is rated for continuous duty at 2.4 MPa discharge pressure, and inspection points are listed in table 12.1.